

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3266-0128:102

Page 1 of 1

CATEGORY: Door Operators

LISTEE: Dor-O-Matic, Inc., 7350 W. Wilson Avenue, Harwood Heights, IL 60706-4708
Contact: Roger Vitt *(317) 715-4420 Fax (317) 715-4473

DESIGN: Model "Ascent" 95000 and "Benchmark" 99000 series door operators for use on swinging doors. These systems are fully automatic Electromechanical swing door operators for commercial pedestrian use. The models connect to a 120 VAC, 60HZ power supply source. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 VAC, 60 HZ

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door operator for non-rated swinging doors when used in exit locations where fire-rated door is not required. For indoor use only. Authority having jurisdiction should be consulted prior to installation.

*Rev. 06-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager